



Laboratory Equipment Manufacturer
www.mrclab.com



INSTRUCTION MANUAL FOR

HOD-020

Homo Mixer




PLEASE READ THIS MANUAL CAREFULLY BEFORE OPERATION

3, Hagavish st. Israel 58817 Tel: 972 3 5595252, Fax: 972 3 5594529 mrc@mrclab.com

MRC.VER.02-11.10

I 、STRUCTURE



II 、SPECIFICATION

Model	HOD-020
Power	AC 110 / 220V, 50 / 60 Hz
Motor	DC 350W
Speed (rpm)	0 ~ 7000
Safety device	Fuse
Coating	Medicine-resisting
Size	399 x 376 x 840
Weight (kg)	17

III · OPERATION INTRODUCTION

1. First , adjust speed control button to “ 0” , then plug into an outlet with specified electric source. Open on switch.
2. Put the container in the stirrer, and keep distance 1 cm from the emulsion board to the container's bottom.
3. Use the height adjuster of splash shield to adjust the splash shield , make it on the face of the liquid
4. Set a proper stirring speed.

IV · ATTENTION

1. Do not use without material.
2. Match the rotation speed to the water speed.
3. Operating in the save current range.

V · INSPECTION

When the machine is out of order, please check up whether:

1. The carbon brush on the two sides of the motor are out of using or in bad contact. (Take them out and renew while out of using.)
2. The fuse burns out or not.

*** If everything down on above instruction, and still not working please send it back to the agent for examination & maintenance. ***